



ATLANTIC COAST Laboratories, Incorporated

630 Churchmans Road
 Newark, DE 19702
 302-266-9121
 Fax: 302-266-8720

Report Of Analysis

Stormdrain Solutions
 333 Beaumont Road
 Devon, PA 19333
 Tel: 1-877-687-7473
 Fax: 610-687-6327
 Invoice Number: 83105

Order #: 00-03-965
 Date: 12/19/00 16:57
 Work ID: Drain Inceptor
 Date Received: 3/29/00
 Date Completed: 4/11/00
 Client Code: Roberts

Certified By: Warren Van Arsdall

Bench Test Results By Sample


Sample 01A
 (External Scrim)
 Collected: 03/23/00

<u>Test Description</u>	<u>Influent</u>	<u>Effluent</u>	<u>Units</u>
Copper, ICP	18.7	0.25	mg/L
Lead, ICP	19.0	1.99	mg/L
Petroleum Hydrocarbons	778	10	mg/L
Zinc, ICP	124	0.25	mg/L

Sample 02A
 (Internal Fiber)
 Collected: 3/23/00

<u>Test Description</u>	<u>Influent</u>	<u>Effluent</u>	<u>Units</u>
Copper, ICP	29.5	0.24	mg/L
Lead, ICP	27.3	1.94	mg/L
Petroleum Hydrocarbons	18630	10	mg/L

<u>Pollutants</u>	<u>Influent</u>	<u>Effluent</u>
Copper, ICP	29.5 mg/L	0.24 mg/L
Lead, ICP	27.3 mg/L	1.94 mg/L
Oil & Grease	778 mg/L	10.0 mg/L
Zinc, ICP	168 mg/L	0.24 mg/L



Total Petroleum Hydrocarbons
 SW-846 Method 3550; EPA Method 418.1 (Sonication, Infrared)

Extraction, Base/Neutral and Acid Extractable Organics
 Wastewater EPA Method 625 (Liq-Liq, Sep Funnel)
 Solids SW 846 Method 3550 (Sonication)
 RCRA TCLP Leachates & Groundwater
 SW 846 Method 3510 (Liq-Liq, Sep Funnel)
 Drinking Water EPA Method 525 (Solid Phase Extraction)